



## Load Bank Test Report

Engine Make/ Model: International GCD325  
 Engine Spec/ Serial: WS4486N1387592  
 Unit Make/ Model: Olympian D200P4  
 Unit Spec/ Serial: OLY00000CNNS00715

Voltage: 480  
 Amperage: 240.6  
 Kilowatts: 200  
 Power Factor 1

	Warm Up	Start	15 Min.	30 Min.	45 Min.	1 Hour	Cool Down
Eng Hours	740.3	740.4	740.6	740.9	741.2	741.4	741.5
Hertz/Cycles	60	60	60	60	60	60	60
Voltage PH1	483	483	483	483	483	483	483
PH2	484	484	484	484	484	484	484
PH3	483	483	483	483	483	483	483
Amperage PH1	0	247	247	247	246	246	0
PH2	0	248	248	248	249	248	0
PH3	0	246	246	246	248	248	0
Kilowatts	0	207	207	207	206	206	0
Oil Pressure	65	60	52	50	50	50	68
Coolant Temperature	108	164°F	190°F	190°F	190°F	190°F	178°F
DC Voltage	25.2	25.2	25.2	24	24	24	24
Ambient Temperature	61	61°F	62°F	62°F	63°F	64°F	64°F

Technician Signature Jonathan Mueller

Test Date 8/21/2025



**8/29/2025**

**CSDG #4684**

### **Generator Check list**

#### Inspection Description

- Yes  No  NA Check coolant level and record freeze protection: - 40
- Yes  No  NA Visual inspection of radiator
- Yes  No  NA Visual inspection of radiator hoses
- Yes  No  NA Check condition of coolant hoses
- Yes  No  NA Check condition of fuel hoses
- Yes  No  NA Check condition of engine belts
- Yes  No  NA Batteries and QTY: 2, 24 Group. (Batteries start unit)
- Yes  No  NA Battery install date if applicable: 6/2022
- Yes  No  NA Genset has battery charger
- Yes  No  NA Genset has coolant heater
- Yes  No  NA Check engine oil level:
- Yes  No  NA Engine oil filters last changed date and HRS: 8/29/2025, 741Hrs
- Yes  No  NA Inspect exhaust system for cracks / leaks
- Yes  No  NA Check rain cap for proper operation
- Yes  No  NA Generator end is 12 lead reconnectable
- Yes  No  NA Generator end has PMG permanent magnet generator
- Yes  No  NA Electronic Engine